

Technical report no. 014-10016818
Revision 0
from 1998-03-12

Customer: Schischek GmbH
Mühlsteig 45
D-90597 Langenzenn

Location of production: As above

Equipment under test: Actuators of product ranges EXV, EXP, EXT

Test specification: EN 60529:1991

Test aims: Test of protective system in accordance with the requirements of protection classification IP67

Test result: The actuators fulfil the requirements of the test specification with respect to the protection classification IP67

This is a translation of the German TÜV test certificate.