



Manufacturer-Declaration for Sensors in hazardous locations

Sensor-Type	SGR-2G	Manufacturer	Schischek GmbH
Function	Room setpoint sensor	Property	passive potential free
Installation in	Zone 1, 2	Associated IS apparatus	Type EXL-IMU-1

Test target

The sensor was tested concerning qualification for installation in hazardous locations.

Application in gas explosion proof zones 1 and 2

Test base is the directive 94/9/EC (ATEX), applied standards are the EN 50014 and EN 50020.

The device must be connected with an intrinsically safe circuit. Suitable is the transducer Type EXL-IMU-1, approved acc. to ATEX with II(1)GD [EEx ia] IIC. PTB03ATEX2092

Proof of intrinsic safety simple circuits in use with EXL-IMU-1

$U_o \leq U_i$	7,5 V < 30V	OK	$C_o \geq C_i + C_{cable}$	$C_i = 0$
$I_o \leq I_i$	5 mA <= 5mA	OK	$L_o \geq L_i + L_{cable}$	$L_i = 0$
$P_o \leq P_i$	10mW <= 10mW	OK	C _{cable} , L _{cable} see wire manufacturer	
Co, Lo see EXL-IMU-1 Data sheet regarding gas group				

Test	Result	Conform
IP-protection class	The device fulfils min. IP20	✓
Metallic enclosure	The magnesium part is less than 6%	✓
Plastic enclosure	Suitable in ambient temperature range -20°C ... +60°C	✓
Electrostatics	In groups IIA and IIB without restrictions applicable, in group IIC observe the note "only wet cleaning"	✓
Fasteners and locking	No particular conditions, not applicable	✓
Earthing (potential equalisation)	Double isolation, no PE, PA necessary	✓
Cable- and wire entry	No particular conditions, the enclosure must meet IP20 after installation	✓
Temperature test	Together with transducer EXL-IMU-1. In case of fault conditions is a temperature increasing of 5K measurable.	✓

Evaluation / additional marks

The room setpoint sensor SGR-2G in combination with transducer EXL-IMU-1 is approved for use in the zone 1 and 2.

Application in gas group IIC, consider the note regarding electrostatic charge.

The tests were applied in the room of manufacturer Schischek GmbH.

Langenzenn, Sep. 24, 2004

Thomas Kellermann
Explosion proof specialist

