



Manufacturer-Declaration for Sensors in hazardous locations

Sensor-Type	TFFK-2G	Manufacturer	Schischek GmbH
Function	Duct temperature humidity sensor	Property	passive potential free
Installation in	Zone 1, 2	Associated IS apparatus	Type EXL-IMU-1

Test target

The sensor was tested concerning qualification for installation in hazardous locations.

Application in gas explosion proof zones 1 and 2

Test base is the directive 94/9/EC (ATEX), applied standards are the EN 50014 and EN 50020.

The device must be connected with an intrinsically safe circuit. Suitable is the transducer Type EXL-IMU-1, approved acc. to ATEX with II(1)GD [EEx ia] IIC. PTB03ATEX2092

Proof of intrinsic safety simple circuits in use with EXL-IMU-1

Terminals 1 - 2 - 3

$U_o \leq U_i$ 7,5 V < 9V OK

$I_o \leq I_i$ 5 mA \leq 5mA OK

$P_o \leq P_i$ 10mW \leq 10mW OK

$C_o \geq C_i + C_{cable}$ $C_i = 10$ pF

$L_o \geq L_i + L_{cable}$ $L_i = 100$ μ H

C_{cable} , L_{cable} see wire manufacturer

C_o , L_o see EXL-IMU-1 Data sheet regarding gas group

Terminals 4 - 5 - 6

$U_o \leq U_i$ 7,5 V < 9V OK

$I_o \leq I_i$ 5 mA \leq 5mA OK

$P_o \leq P_i$ 10mW \leq 10mW OK

$C_o \geq C_i + C_{cable}$ $C_i = 0$

$L_o \geq L_i + L_{cable}$ $L_i = 0$

Test	Result	Conform
IP-protection class	The device fulfils min. IP20	✓
Metallic enclosure	The magnesium part is less than 6%	✓
Plastic enclosure	Suitable in ambient temperature range -10°C ... +50°C	✓
Electrostatics	In groups IIA and IIB without restrictions applicable, in group IIC observe the note "only wet cleaning"	✓
Fasteners and locking	No particular conditions, not applicable	✓
Earthing (potential equalisation)	Double isolation, no PE, PA necessary	✓
Cable- and wire entry	No particular conditions, the enclosure must meet IP20 after installation	✓
Temperature test	Together with transducer EXL-IMU-1. In case of fault conditions is a temperature increasing of 5K measurable.	✓

Evaluation / additional marks

The duct temperature humidity sensor TFFK-2G in combination with transducer EXL-IMU-1 is approved for use in the zone 1 and 2.

Application in gas group IIC, consider the note regarding electrostatic charge.

The tests were applied in the room of manufacturer Schischek GmbH.

Langenzenn, Oct. 24, 2003

Thomas Kellermann
Explosion proof specialist

