

Manufacturer's Declaration for Sensors for Use in Hazardous Areas

Product: Contact temperature sensor

Type: TFR-AN-2G3D

Installation in: Zones 1, 2 and 22

Manufacturer: Schischek GmbH

Properties: passive, potential-free Associated apparatus: EXL-IMU-1

The contact temperature sensor was evaluated for installation and use in explosive atmospheres of zones 1, 2 and 22. Directive 2014/34/EU was used as base for the evaluation. Moreover, the standards EN 60079-0, EN 60079-11 and EN 60079-31 were applied. The contact temperature sensor is simple apparatus in the meaning of EN 60079-11 sub-clause 5.7 and has to be operated with an intrinsically-safe circuit. Measuring transducer type EXL-IMU-1 with EC type examination

number PTB 03 ATEX 2092 and Ex marking II (1) G D [EEx ia] is suitable. The transducer may only be installed and operated in non-hazardous atmospheres.

Verification of intrinsic safety for simple electrical apparatus in conjunction with EXL-IMU-1

 $U_o \leq U_i$ l_o ≤ l_i

 $7,5 \text{ V} \leq 30 \text{ V}$ $5 \text{ mA} \leq 5 \text{ mA}$ OK OK $C_o \geq C_i + C_{cable}$

 $C_i = 0 \mu F$

 $L_o \ge L_i + L_{Cable}$

 $L_i = 0 \text{ mH}$

Phone: +49 9101 9081 0

Fax: +49 9101 9081 77

info-de@schischek.com

 $P_o \le P_i$

10 mW ≤ 10 mW

C_{Cable}, L_{Cable}: refer to cable manufacturer's data

Co, Lo: values according to gas group, refer to data sheet

of EXL-IMU-1

Test Result

IP protection

The equipment complies with min. 1P65

Evaluation of metallic parts **Evaluation of plastics**

Magnesium, titanium and zirconium content < 7,5%

Suitable for ambient operating temperature range of -30°C..+60°C

Electrostatics

No limitations for use in groups IIA and IIB, for use in group IIC the warning "Only wet

Fasteners

cleaning" or similar applies No particular conditions, not applicable

Grounding

Plastic enclosure, no grounding necessary/grounded via structural parts respectively

Cable entries

The cables have to be protected against mechanical and thermal damage, after

installation IP65 has to be complied with

Temperature rise test

No temperature rise >5K measured in conjunction with switching amplifier of type

EXL-IMU-1; sensors are, among others, suitable for -30°C to +60°C

Final evaluation

The contact temperature sensor of type TFR-AN-2G3D is suitable for use in conjunction with measuring transducer of type EXL-IMU-1 in zones 1, 2 and 22. The information contained in the specification sheet/user manual has to be observed. Likewise, the warning statements referring to electrostatics have to be observed. After installation IP protection IP65 has to be guaranteed.

Langenzenn, April 20, 2016

Arno Butzke

Explosion protection representative